INSTALLATION INSTRUCTIONS



LED SLIM SURFACE MOUNT 12"/15"



В

Mounting

screws

3CCT Selectable



D

Mounting

Plate

WARNING

FOR YOUR SAFETY READ AND UNDERSTAND INSTRUCTIONS COMPLETELY BEFORE STARTING INSTALLATION. BEFORE WIRING TO POWER SUPPLY, TURN OFF ELECTRICITY AT THE FUSE OR CIRCUIT BREAKER BOX.



CAUTION: RISK OF FIRE

SUPPLY CONDUCTORS (POWER WIRES) CONNECTING THE FIXTURE MUST BE RATED MINIMUM 90°C. IF UNCERTAIN, CONSULT AN ELECTRICIAN.



CAUTION: RISK OF ELECTRIC SHOCK

DISCONNECT POWER BEFORE OR CIRCUIT BREAKER BEFORE INSTALLING OR SERVICING



SAFETY PRECAUTIONS



FOR SAFETY, READ AND UNDERSTAND INSTRUCTIONS COMPLETELY BEFORE STARTING INSTALLATION. ELECTRICITY SHOULD BE TURNED OFF AT THE FUSE OR THE CIRCUIT BREAKER BOX BEFORE INSTALLING THE FIXTURE. ALL ELECTRICAL CONNECTIONS MUST BE IN ACCORDANCE WITH N. E. C. OR YOUR LOCAL CODE.

COMPATIBLE DIMMERS

PACKAGE CONTENTS

Α

LEDLov

Profile Flsh Mount

LUTRON	LEVITON
• PD-6WCL	• 6681
• DVCL-153P	• 6672
• CTCL-153P	
MACL-153M	
• TGCL-153P	

ASSEMBLY INSTRUCTIONS

- 1. PREPARING FOR INSTALLATION: DISCONNECT ELECTRICAL POWER BEFORE INSTALLING OR SERVICING ANY PART OF THIS FIXTURE.
- 2. THIS PRODUCT SHALL BE SURFACE MOUNTED WITH JUNCTION BOX OR NON-COMBUSTIBLE SURFACE ABOVE 4 FEET (1.2 METER) HIGH. USER SHOULD PREPARE NECESSARY ACCESSORIES AND SPARE PARTS (NOT PROVIDED) INCLUDING JUNCTION BOX AND SCREWS.

TOOLS REQUIRED















Electrical Tape



Safety Goggles INSTALLATION (CONSULT A QUALIFIED ELECTRICIAN BEFORE INSTALLING)


C

Wire nuts


M

(3 pcs)

Step 1: Hold Mounting Bracket up to junction box with flange facing down. Align breach side of the Moungting Bracket parallel to nearest wall. Screws mounting bracket to J-box.




Step 2: Before working wire connection, attach to hook side of safety cable Mounting Bracket.




WARNING:

Changes or modifications not expressly approved by the party responsible for compliance could void the user's authority to operate the equipment.


Step 3: With the power turned off, connect the green ground wire from the fixture to the bare copper ground wire from the junction box using a wire nut (if housing wiring does not include a ground wire, consult your local electrical code for approved grounding methods). Use wire nuts to connect black fixture wire to the black power supply wire and white fixture wire to the white power supply wire.



Step 4: Attach provided to indents (opening) of the Mounting Bracket and align mounting tabs on back of the fixture with indents in the Mounting Bracket.



Step 5: Using sticker on the fixture (reference point for mounting tab) and on the ceiling as reference point, lift fixture up to the ceiling and rotate clockwise until fixture is secured (45-degree turn until it locks).





www.jescolighting.com support@iescolighting.com Tech Support: 855.592.0029

15 Harbor Park Drive Port Washington, NY 11050 **Main Line:** 800.527.7796 Fax Line: 855.265.5768

City of Industry, CA 91746

Main Line: 855.654.0110 Fax Line: 626.333.2955